

***Annual Drinking Water Quality Report for 2015***  
***Cumberland County Water System***  
***PWSID No. 5049150***

**INTRODUCTION**

This Annual Drinking Water Quality Report for the 2015 calendar year is designed to inform you about your drinking water quality. Our goal is to provide you with a safe and dependable supply of drinking water, and we want you to understand the efforts we make to protect your water supply. The quality of your drinking water must meet state and federal requirements administered by the Virginia Department of Health (VDH).

**If you have questions about this report, please contact:**

---

Gary Thompson: 434-603-1038

---

**If you want additional information about any aspect of your drinking water or want to know how to participate in decisions that may affect the quality of your drinking water, please contact**

---

Gary Thompson: 434-603-1038

---

**The times and location of regularly scheduled board meetings are as follows:**

---

The 2<sup>nd</sup> Tuesday of each Month at 7:00 p.m. / County Courthouse

---

**GENERAL INFORMATION**

As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and can pick up substances resulting from the presence of animals or from human activity. Contaminants in source water may be naturally occurring substances, or may come from septic systems, discharges from domestic or industrial wastewater treatment facilities, agricultural and farming activities, urban storm water runoff, residential uses, and many other types of activities. Water from surface sources is treated to make it drinkable while groundwater may or may not have any treatment.

Contaminants that may be present in source water include:

- **Microbial contaminants**, such as viruses and bacteria, which may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife.
- **Inorganic contaminants**, such as salts and metals, which can be naturally-occurring or result from urban storm water runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.
- **Pesticides and herbicides**, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.
- **Organic chemical contaminants**, including synthetic and volatile organic chemicals, which are byproducts of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems.
- **Radioactive contaminants**, which can be naturally-occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of certain contaminants in water and provided by public water systems. Food and Drug Administration regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

All drinking water, including bottled drinking water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline (800-426-4791).

## VULNERABLE POPULATIONS

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-4791).

## SOURCE(S) AND TREATMENT OF YOUR DRINKING WATER

The source of your drinking water is groundwater drawn from three drilled wells. All wells are treated with a sodium hypochlorite solution for continuous disinfection and with a sodium bicarbonate solution for pH adjustment and corrosion control. Well No.3 includes greensand filtration in which iron, manganese and radium are removed.

A source water assessment of our system was conducted in 2003 by the Virginia Department of Health. The wells were determined to be of high susceptibility to contamination using the criteria developed by the state in its approved Source Water Assessment Program.

The assessment report consists of maps showing the source water assessment area, an inventory of known land use activities of concern, and documentation of any known contamination within the last 5 years. The report is available for review by contacting Gary Thompson at 434-603-1038.

## WATER CONSERVATION TIPS

Did you know that the average U.S. household uses approximately 350 gallons of water per day? Luckily, there are many low-cost or no-cost ways to conserve water. Water your lawn at the least sunny times of the day. Fix toilet and faucet leaks. Take short showers - a 5 minute shower uses 4 to 5 gallons of water compared to up to 50 gallons for a bath. Turn the faucet off while brushing your teeth and shaving; 3-5 gallons go down the drain per minute. Teach your kids about water conservation to ensure a future generation that uses water wisely. Make it a family effort to reduce next month's water bill!

## DEFINITIONS

Contaminants in your drinking water are routinely monitored according to federal and state regulations. The table on the next page shows the results of this monitoring for the period of January 1st through December 31st, 2014. In the table and elsewhere in this report you will find many terms and abbreviations you might not be familiar with. The following definitions are provided to help you better understand these terms:

*Non-detects (ND)* - lab analysis indicates that the contaminant is not detectable, based on the limits of the analytical equipment used.

*Parts per million (ppm) or Milligrams per liter (mg/l)* - one part per million corresponds to one minute in two years or one penny in \$10,000.

*Parts per billion (ppb) or Micrograms per liter (pg/l)*- one part per billion corresponds to one minute in 2,000 years, or one penny in \$10,000,000.

*Picocuries per liter (pCi/L)*- picocuries per liter is a measure of the radioactivity in water.

*Nephelometric Turbidity Unit (NTU)* - nephelometric turbidity unit is a measure of the cloudiness of water. Turbidity in excess of 5 NTU is just noticeable to the average person.

*Action Level (AL)* - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

*Treatment Technique (TT)* - a required process intended to reduce the level of a contaminant in drinking water.

*Maximum Contaminant Level Goal (MCLG)* - the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

*Maximum Contaminant Level (MCL)* - the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

*Maximum Residual Disinfectant Level Goal (MRDLG)* -the level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

*Maximum Residual Disinfectant Level (MRDL)* -the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

*Variations and exemptions* - state or EPA permission not to meet an MCL or a treatment technique under certain conditions.

## WATER QUALITY RESULTS

We routinely monitor for various contaminants in the water supply to meet all regulatory requirements. The table lists only those contaminants that had some level of detection. Many other contaminants have been analyzed but were not present or were below the detection limits of the lab equipment.

<b>Inorganic Contaminants</b>						
Contaminant / Unit of Measurement	MCLG	MCL	Level Found in Range	Violation	Date of Sample	Typical Source of Contamination
Barium (ppm)	2	2	High: 0.012 Range: 0.011 to 0.012	No	January 2013 and June 2015	Discharge of drilling wastes; Discharge from metal refineries; Erosion of natural deposits
<b>Radiological Contaminants</b>						
Contaminant/Unit of Measurement	MCLG	MCL	Level Found / Range	Violation	Date of Sample	Typical Source of Contamination
Alpha emitters (pCi/L)	0	15	High: 8.1 Range: 1.9 - 8.1	No	January 2013 & February 2015	Erosion of natural deposits
Combined Radium (pCi/L)	0	5	High: 3.3 Range: ND - 3.3	No		Erosion of natural deposits

<b>Lead and Copper</b>						
Contaminant/Unit of measurement	MCLG	MCL	Level Found / Range	Exceedances	Date of Sample	Typical Source of Contamination
Lead (ppb)	0	AL = 15	4.9 (90 <sup>th</sup> percentile) Range: ND - 20.4 of the twenty samples collected, one exceeded the AL	No	June 2015	Corrosion of household plumbing systems; Erosion of natural deposits
Copper (ppm)	1.3	AL = 13	0.33 (90 <sup>th</sup> percentile) Range: ND - 0.52. Of the twenty samples collected, none exceeded the AL.	No	June 2105	Corrosion of household plumbing systems; Erosion of natural deposits
<b>Volatile Organic Contaminants</b>						
Contaminant / Unit of Measure	MCLG	MCL	Level Found / Range	Violation	Date of Sample	Typical Source of Contamination
1,2 - Dichloroethane (ppb)	0	5	High: 0.7 Range: 0.6 - 0.7	No	March 2015	Discharge from industrial chemical factories
<b>Disinfection Byproducts</b>						
Contaminant /	MCLG	MCL	Level Found /	Violation	Date of	Typical Source of

Unit of Measure			Range		Sample	Contamination
TTHMs Total Trihalomethanes (ppb)	N/A	80	10	No	September 2015	By-product of drinking water disinfectant
Chlorine (ppm)	MRDLG = 4	80	Highest Qlty. Ave. 0.83 Range: 0.49 - 1.09	No	Monthly 2015	Water additive used to control microbes
<b>Microbiological Contaminants</b>						
Contaminant / Unit of Measure	MCLG	MCL	Level Found	Violation	Date of Sample	Typical Source of Contamination
Total Coiform Bacteria	0	1 positive monthly sample	Of five samples collected one was positive	No	March 2015	Naturally present in the environment

SODIUM: According to results of the chemical analyses for Metals based on a sample collected on January 15, 2013 for Well No. 3, the sodium in the treated water is 27 mg/L. This is above the EPA recommended optimal level of less than 20 mg/L for sodium in drinking water, which is established for those individuals on a "strict" sodium intake diet.

The state allows us to monitor for some contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our results, though representative, are more than one year old.

The U.S. Environmental Protection Agency sets MCLs at very stringent levels. In developing the standards EPA assumes that the average adult drinks 2 liters of water each day throughout a 70-year life span. EPA generally sets MCLs at levels that will result in no adverse health effects for some contaminants or a one-in-ten-thousand to one-in-one-million chance of having the described health effect for other contaminants.

#### ADDITIONAL INFORMATION FOR LEAD

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Cumberland County Water System is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.

We are pleased to report to you that there were no detections of total HAA5's (Haloacetic Acids) in the samples collected during calendar year 2015.

#### 2015 NOVs:

- (1) 09-17-2015 Lead consumer notice (LCR). PN completed 10-02-2015. The Lead consumer notice was required to be sent out by July 2015 and the County corrected this issue by September 2015. The County will be diligent in sending out notices in a timely manner. There are no adverse health effects due to this violation.
- (2) 05-14-2015 Monitoring (TCR), Routine minor; The County failed a minor monthly bacti test. The following month, two retests were required, completed and passed. This was also required for a second continuous month, which the County failed to complete. The County will be diligent in obtaining all required tests in the future. There are no adverse health effects due to this violation.